



Product Service

CERTIFICATE

No. Z2 099333 0044 Rev. 05

Model(s):

LR6-72BP-xxxM, (xxx=350 to 380 in step of 5)
 LR6-60BP-xxxM, (xxx=290 to 315 in step of 5)
 LR6-72DG-xxxM, (xxx=330 to 360 in step of 5)
 LR6-60DG-xxxM, (xxx=275 to 300 in step of 5)
 LR6-72PD-xxxM, (xxx=345 to 370 in step of 5)
 LR6-60PD-xxxM, (xxx=290 to 305 in step of 5)
 LR6-72HBD-xxxM, (xxx=360 to 395 in step of 5)
 LR6-60HBD-xxxM, (xxx=300 to 325 in step of 5)
 LR6-72HIBD-xxxM, (xxx=360 to 380 in step of 5)
 LR6-60HIBD-xxxM, (xxx=300 to 325 in step of 5)
 LR6-78HIBD-xxxM, (xxx=395 to 410 in step of 5)
 LR6-72HIBD-xxxMC, (xxx=360 to 380 in step of 5)
 LR6-60HIBD-xxxMC, (xxx=300 to 325 in step of 5)
 LR6-78HBD-xxxM, (xxx=395 to 410 in step of 5)
 LR6-72HPD-xxxM, (xxx=360 to 385 in step of 5)
 LR6-60HPD-xxxM, (xxx=300 to 320 in step of 5)
 LR6-72HBD-xxxMC, (xxx=360 to 395 in step of 5)
 LR6-60HBD-xxxMC, (xxx=300 to 325 in step of 5)
 LR6-72OPD-xxxM, (xxx=370 to 410 in step of 5)
 LR6-60OPD-xxxM, (xxx=325 to 345 in step of 5)
 LR6-72MBD-xxxM, (xxx=365 to 385 in step of 5)
 LR6-60MBD-xxxM, (xxx=305 to 320 in step of 5)
 LR6-72MPD-xxxM, (xxx=365 to 385 in step of 5)
 LR6-60MPD-xxxM, (xxx=305 to 320 in step of 5)
 LR4-72HBD-xxxM (xxx=415 to 455 in step of 5)
 LR4-60HBD-xxxM (xxx=345 to 375 in step of 5)
 LR4-72HIBD-xxxM (xxx=415 to 445 in step of 5)
 LR4-60HIBD-xxxM (xxx=345 to 360 in step of 5)
 The suffix BP is meaning double glass PV modules with bifacial solar cells,
 the suffix DG is meaning double glass modules,
 the suffix PD is meaning double glass PV modules with PERC cells,
 the suffix HBD, HIBD is meaning double glass PV modules with bifacial half
 solar cells, the suffix OPD is meaning double glass shingling module types,
 the suffix HPD is meaning double glass PV modules with PERC half solar
 cells, the suffix MBD is meaning double glass PV modules with bifacial MBB
 cells, the suffix MPD is meaning double glass PV modules with MBB cells.
 xxx is standing for rated output power at STC.

Parameters:

Severity of
 Salt mist test: Severity 6
 Safety Class: Class II
 Maximum System Voltage: 1500 V DC
 Construction: Framed or frameless, with Junction
 box, cable and connector.
 Fire Safety Class: Class C according to UL790

Tested according to:

IEC 61701:2011
 IEC 61215-1:2016
 IEC 61215-1-1:2016
 IEC 61215-2:2016
 IEC 61730-1:2016
 IEC 61730-2:2016

Production Facility(ies):

099605, 002875, 001192, 090968, 099606, 099626, 096558,
 102892, 097323, 103410, 103841

TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD
 ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFICAT